

DR. RALPH DERRA

Öffentlich bestellter und vereidigter Sachverständiger für Verpackungsmaterialien, Boden- und Luftanalysen



ISEGA – Forschungs- und Untersuchungs-Gesellschaft mbH
Aschaffenburg



63704 Aschaffenburg, Postfach 100565
63741 Aschaffenburg, Zeppelinstr. 3-5
Germany
Telefon +49 (0) 60 21 / 49 89-0
Telefax +49 (0) 60 21 / 49 89-30
Email isega@t-online.de
http://www.isega.de

16 March 2004
Dr. Dr-sh

TEST CERTIFICATE

423 P 04

for Messrs: Pfleiderer Teisnach GmbH & Co. KG, Teisnach/Germany

Product: Paper

Designation: Sulphate mixed paper flame retardant
Sodium hydrogen carbonate-Star flame retardant

The products manufactured by the company mentioned above are paper grades equipped with a flame retardant.

The sample material submitted was examined by us according to the

DIN 4102-1 for its material specification.

The results are summarized in the test report 1540/55 issued by ISEGA Forschungs- und Untersuchungsgesellschaft Aschaffenburg of 19 February 2004.

The products Sulphate mixed paper flame retardant and Sodium hydrogen carbonate-Star flame retardant are in conformity with the demands on the material specification B2 (edge flaming) and on the material specification B1 according to

DIN 4102-1

with regard to the specifications mentioned above.



Kranke
(Kranke)

Dipl.-Ingenieur (FH)

h:\orga\gutachten\p423e.doc